

FIELD ID/LOCATION	ACTION TAKEN	RETEST REQUIRED	
SMA-1-KITCHEN FP4-P	SINK IS LABELED AS NON FOOD PREP	NO FURTHER TESTING REQUIRED	
SMA-1-KITCHEN-KT-P	FLUSHED	YES. WILL RETEST	
SMA-1-H CAFÉ-WC-P IN HALL OUTSIDE OF CAF.	OLD FOUNTAIN REMOVED. NEWER FOUNTAIN IN CAF CAN BE UTILIZED.	NO FURTHER ACTION REQUIRED	
SMA-1-1-2-SB-P	SINK BUBBLER AND WATER LINE WAS REPLACED. WATER TURNED OFF UNTIL RETEST	YES. WILL RETEST	
SMA-1-96-SB-P	SINK BUBBLER AND WATER LINE WAS REPLACED. WATER TURNED OFF UNTIL RETEST	YES. WILL RETEST	
SMA-1-GYM-WC-P	OLD FOUNTAIN REMOVED. NEWER FOUNTAIN IN HALLWAY CAN BE UTILIZED.	NO FURTHER ACTION REQUIRED	
PLC-1-NURSE-NS-P	WATER FILTER WAS INSTALLED IN SINK	YES. WILL RETEST	