



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Stafford SD Art Center School
PAS Project ID : P21-07255

Matrix : Drinking Water
Report Date : 7/22/2021

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-07255-01	SAC-1-H Dressing Rm-WC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:10	7/20/21 16:14
P21-07255-02	SAC-1-H Dressing Rm-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:11	7/20/21 16:29
P21-07255-03	SAC-1-S. Store-FP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:13	7/20/21 16:32
P21-07255-04	SAC-1-S. School-FP2-P	Lead	2.23	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:14	7/20/21 16:36
P21-07255-05	SAC-1-Lobby-WC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:15	7/20/21 16:55
P21-07255-06	SAC-1-Lobby-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/16/21 07:16	7/20/21 17:02

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director

CHAIN OF CUSTODY



Customer: **PARS Environmental**
 Address: **500 Horizon Drive, Suite 540**
Robbinsville, NJ 08691
 Phone: **(609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini**

School Name: **Stafford SD ART Center School**
 School Address:
 Sampled By: **Jessica Perrini**
 Print Name: **Jessica Perrini**
 RESULTS TO: **jperrini@montrose-env.com**

Sample ID Location	Date / / Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Pres. Preserv	# Containers	Glass or Plastic	Analysis	LAB ID
See Attached COC All samples for Lead water Analysis 200.8 (P21-07255) (-01 thru -06)		DW	Grab	N	N	1	250 ml Plastic	Lead	
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		
	DW	Grab	N	N	1	250 ml Plastic	Lead		

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB *(initials)*

Page of Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with Initials: **7/19/21 @ 14:00**

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Jessica Perrini	Jessica Perrini		7/16/21
Received:	I Birmingham	[Signature]		7/19/21 10:07
Relinquished:	I Birmingham	[Signature]		7/15/21 12:15
Received:				
Relinquished:				
Received:				



Facility Name: **Stafford Art Center**

Date:

7/16/21

Sample #	Sample ID	Sample Time	Comments
1	SAC - 1 - HDressing Rm - WC1 - P	7:10	
2	SAC - 1 - HDressing Rm - WC2 - P	7:11	
3	SAC - 1 - S. Store - FP1 - P	7:13	
4	SAC - 1 - S. School - FP2 - P	7:14	
5	SAC - 1 - Lobby - WC7 - P	7:15	
6	SAC - 1 - Lobby - WC2 - P	7:16	

221-02855 -01
 -02
 -03
 -04
 -05
 P81-02855 -06

Signature of Sampler:

Chloe Ray

Sample ID Guide:
 Bldg ID - Flr - Rm - Direction - Type (- Faucet #)