

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
 Project ID : Stafford SD Oxycoccus School

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-07251-01	PAS	NJDEP 15001	7/16/2021	6:02	SM 3113 B	7/21/2021	11:35	-0.44	2.00	1	N	ND
SOS-1-Kitchen-FP-P	N	P21-07251-02	PAS	NJDEP 15001	7/16/2021	6:03	SM 3113 B	7/21/2021	11:39	3.72	2.00	1	N	
SOS-1-H29-WC-P	N	P21-07251-03	PAS	NJDEP 15001	7/16/2021	6:05	SM 3113 B	7/21/2021	12:00	-0.39	2.00	1	N	ND
SOS-1-H29-BT-P	N	P21-07251-04	PAS	NJDEP 15001	7/16/2021	6:06	SM 3113 B	7/21/2021	12:04	-0.49	2.00	1	N	ND
SOS-1-32-TS-P	N	P21-07251-05	PAS	NJDEP 15001	7/16/2021	6:08	SM 3113 B	7/21/2021	12:07	0.150	2.00	1	N	ND
SOS-1-Nurse-NS-P	N	P21-07251-06	PAS	NJDEP 15001	7/16/2021	6:09	SM 3113 B	7/21/2021	12:11	2.14	2.00	1	N	
SOS-1-7-SB-P	N	P21-07251-07	PAS	NJDEP 15001	7/16/2021	6:11	SM 3113 B	7/21/2021	12:14	0.550	2.00	1	N	ND
SOS-1-24-SB-P	N	P21-07251-08	PAS	NJDEP 15001	7/16/2021	6:12	SM 3113 B	7/21/2021	12:18	-0.19	2.00	1	N	ND
SOS-1-10-SB-P	N	P21-07251-09	PAS	NJDEP 15001	7/16/2021	6:16	SM 3113 B	7/21/2021	12:21	1.15	2.00	1	N	J
SOS-1-21-SB-P	N	P21-07251-10	PAS	NJDEP 15001	7/16/2021	6:20	SM 3113 B	7/21/2021	12:25	7.73	2.00	1	N	
SOS-1-H14-WC-P	N	P21-07251-11	PAS	NJDEP 15001	7/16/2021	6:21	SM 3113 B	7/21/2021	12:29	0.0062	2.00	1	N	ND
SOS-1-H14-BT-P	N	P21-07251-12	PAS	NJDEP 15001	7/16/2021	6:23	SM 3113 B	7/21/2021	12:32	-0.04	2.00	1	N	ND
SOS-1-Admin Lounge-TS-P	N	P21-07251-13	PAS	NJDEP 15001	7/16/2021	6:27	SM 3113 B	7/21/2021	12:43	1.44	2.00	1	N	J
SOS-1-Admin Lounge-WC-P	N	P21-07251-14	PAS	NJDEP 15001	7/16/2021	6:28	SM 3113 B	7/21/2021	12:47	-0.44	2.00	1	N	ND
SOS-1-H Facilities-WC-P	N	P21-07251-15	PAS	NJDEP 15001	7/16/2021	6:29	SM 3113 B	7/21/2021	12:51	-0.39	2.00	1	N	ND