

Appendix D
Excel Template for Lead Results

Client : PARS Environmental
Project ID : McKinley Elementary School, 1000 Mc Kinley Ave., Manahawkin

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
SMA-Field Blank	N	P21-09470-01	PAS	NJDEP 15001	8/20/2021	7:00	SM 3113 B	8/26/2021	13:42	-0.02	2.00	1	N	ND
SMA-1-Kitchen-KT-R	N	P21-09470-02	PAS	NJDEP 15001	8/20/2021	7:01	SM 3113 B	8/26/2021	13:46	9.88	2.00	1	N	
SMA-1-Kitchen-KT-F	Y	P21-09470-03	PAS	NJDEP 15001	8/20/2021	7:04	SM 3113 B	8/26/2021	13:50	0.390	2.00	1	N	ND
SMA-1-96-SB-R	N	P21-09470-04	PAS	NJDEP 15001	8/20/2021	7:06	SM 3113 B	8/26/2021	14:35	23.5	4.00	2	N	
SMA-1-96-SB-F	Y	P21-09470-05	PAS	NJDEP 15001	8/20/2021	7:07	SM 3113 B	8/26/2021	13:58	0.800	2.00	1	N	ND
SMA-1-102-SB-R	N	P21-09470-06	PAS	NJDEP 15001	8/20/2021	7:09	SM 3113 B	8/26/2021	14:28	9.26	2.00	1	N	
SMA-1-102-SB-F	Y	P21-09470-07	PAS	NJDEP 15001	8/20/2021	7:11	SM 3113 B	8/26/2021	14:31	0.190	2.00	1	N	ND

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib
- ST= Steamer